

San Dieguito

Board of Trustees
 Joyce Dalessandro
 Linda Friedman
 Barbara Groth
 Beth Hergesheimer
 Deanna Rich

Superintendent
 Ken Noah

Union High School District

710 Encinitas Boulevard, Encinitas, CA 92024
 Telephone (760) 753-6491
 www.sduhsd.net

Business Services Division
 Stephen G. Ma, Associate Superintendent
 Fax (760) 943-3508

July 1, 2008

Bob Hickey, Sales Representative
 Conservation Plus

Dear Bob,

I would like to thank you for all your work and assistance in getting the Watermiser Flow Control Valves delivered to our Diegueno Middle School campus. The flow control devices have all been installed and we have been able to take measurements of the water flow rates, before and after installation.

11 faucets were used to measure water flow to gauge results. These sinks are located in different buildings spread out over the campus to get a random sampling of results as follows.

Before GPM	Room	Building/Rm type	After GPM	% of Savings
2.25	Boys	Locker/Restroom	1.78	21%
2.06	Girls	Media Center	1.50	27%
1.87	Boys	Media Center	1.41	25%
2.06	Staff	Restroom (Men's)	1.50	27%
2.06	Staff	Restroom (Women's)	1.50	27%
1.41	Lunch	Cafeteria Sink	1.12	20%
5.62	F-1	Science Lab	1.31	77%
7.31	F-2	Science-back sink	1.22	83%
4.50	G-3	Science 3 rd sink	1.31	71%
1.59	G-3	Science 2 nd sink	1.12	30%
7.87	G-3	Science 1 st sink	1.31	83%

Using these 11 faucets as the basis for our data, the average water savings at Diegueno Middle School is 44.64%

We hope to continue working with you and the Water District in our efforts to find ways to conserve water. It is our hope to have the Flow Control Valves installed at all of our sites in the near future.

Once again, thank you on behalf of the Facilities Staff of the San Dieguito Union High School District.

Sincerely yours,

Javier Lopez